



HAINES BOROUGH, ALASKA

P.O. BOX 1209, HAINES, ALASKA 99827

Administration 907.766.2231 ♦ (fax) 907.766.2716

Tourism 907.766.2234 ♦ (fax) 907.766.3155

Police Dept. 907.766.2121 ♦ (fax) 907.766.2190

Fire Dept. 907.766.2115 ♦ (fax) 907.766.3373

January 8, 2014

TO ALL PLAN HOLDERS OF RECORD HAINES SCHOOL FANS REPLACEMENT

The following addendum was issued today. Please acknowledge receipt of the addendum on your bid documents. If you have already submitted your bid, you may fax a modification to the Clerk's Office. Thank you.

Sincerely,

A handwritten signature in purple ink that reads "Julie Cozzi".

Julie Cozzi, MMC
Interim Borough Manager

HAINES SCHOOL FANS REPLACEMENT



ADDENDUM TO THE CONTRACT DOCUMENTS

Addenda No.: (2) Two

Bid Submission Deadline:

January 15, 2014

Previous Addenda: One

2:00 p.m. Local Time

Issued By: Haines Borough
P.O. Box 1209
Haines, Alaska 99827

DATE ADDENDUM ISSUED:

January 8, 2014

The following items of the Contract are modified as herein indicated. All other items remain the same.

- Item #1: Reference Sheet E201: Add Note 5 - Existing MCC3 Factory Order Number is F/O # 22466130-078.
- Item #2: Specification Section 230713 3.2 Paragraph F; Delete and replace as follows:
Ducts Exposed in Mechanical Room with Board Insulation: Finish with Canvas Jacket.
- Item #3: Specification Section 230713 3.3 Paragraph A; Revise subparagraph 2. as follows:
Delete the word 'Board'.
- Item #4: Specification Section 230713 3.3 Paragraph A; Add subparagraph 2.c. as follows:
AHU-3 Exhaust Air: Insulate duct from plenum to AHU-3 exhaust air connection. .

By: 
Julie Cozzi
Interim Borough Manager

Please be sure to note on the *Bid and Bid Schedule* form that you have received this addendum.