



HAINES BOROUGH, ALASKA

P.O. BOX 1209, HAINES, ALASKA 99827
Administration 907.766.2231 ♦ (fax) 907.766.2716
Tourism 907.766.2234 ♦ (fax) 907.766.3155
Police Dept. 907.766.2121 ♦ (fax) 907.766.2190
Fire Dept. 907.766.2115 ♦ (fax) 907.766.3373

November 19, 2013

TO ALL PLAN HOLDERS OF RECORD

Haines Gym, Pool, & Chilkat Center Doors and Haines Gym Mat Hoist

The following addendum was issued today. Please acknowledge receipt of the addendum on your bid documents. Thank you.

Sincerely,

A handwritten signature in black ink that reads "Krista Kielsmeier". The signature is written in a cursive, flowing style.

Krista Kielsmeier
Administrative Assistant



ADDENDUM TO THE CONTRACT DOCUMENTS

Addenda No.: (1) One

Bid Submission Deadline:

December 2, 2013

Previous Addenda: None

2:00 p.m. Local Time

Issued By: Haines Borough
P.O. Box 1209
Haines, Alaska 99827

DATE ADDENDUM ISSUED: November 19, 2013

To: All Planholders of Record

This addendum forms part of and modifies the contract documents as noted below. All other items remain the same. Bidders must acknowledge receipt of this addendum in the space provided on the bid form. Failure to do so may submit Bidder to disqualification. This addendum consists of 1 page and has been issued and is posted online. Refer to the Haines Borough website at: <http://www.hainesalaska.gov/rfps>.

ADDENDUM NO. 1

PROJECT MANUAL:

SECTION 081416 – FLUSH WOOD DOORS

Delete Section 2.5 C.2 which states “Glazing: Factory install glazing in doors indicated to be factory finished.”

DRAWINGS:

SHEET A204 – DOOR TYPES, DETAILS, HARDWARE & DOOR SCHEDULE

Door Schedule: **Add** Note B – 1/4” fully tempered glazing
Add Note B to all type “A” doors (100, 101, 102, 105 & 106)

END OF ADDENDUM NO. 1