



HAINES BOROUGH, ALASKA

P.O. BOX 1209, HAINES, ALASKA 99827

Administration 907.766.2231 ♦ (fax) 907.766.2716

Tourism 907.766.2234 ♦ (fax) 907.766.3155

Police Dept. 907.766.2121 ♦ (fax) 907.766.2190

Fire Dept. 907.766.2115 ♦ (fax) 907.766.3373

July 9, 2013

TO ALL BID DOCUMENT HOLDERS
HAINES GYM, POOL, & CHILKAT CENTER DOORS AND HAINES
GYM MAT HOIST

The following second addendum was issued today. Please acknowledge receipt of the addendum on your bid documents. Thank you.

Sincerely,

A handwritten signature in blue ink, appearing to read "Michelle Webb".

Michelle Webb
Deputy Clerk

ADDENDUM 2
Haines Gym, Pool, & Chilkat Center Doors and Haines Gym Mat Hoist
Haines, Alaska

July 9, 2013

TO ALL PLAN HOLDERS OF RECORD:

This addendum forms part of and modifies the contract documents as noted below. Bidders must acknowledge receipt of this addendum in the space provided on the bid form. Failure to do so may submit Bidder to disqualification. This addendum consists of 1 page.

PLANS SET:

1. Sheet A205:

ADD General Note No.1 - Run required hoist wiring and conduit to 3 phase power in panel located in either the boiler room or air handler room (Both are approx 100' away from hoist location)

ADD General Note No.2 - Locate hoist controls by equipment room (Approx 25' away from hoist location)

END OF ADDENDUM 1