



HAINES BOROUGH, ALASKA

P.O. BOX 1209, HAINES, ALASKA 99827

Administration 907.766.2231 ♦ (fax) 907.766.2716

Tourism 907.766.2234 ♦ (fax) 907.766.3155

Police Dept. 907.766.2121 ♦ (fax) 907.766.2190

Fire Dept. 907.766.2115 ♦ (fax) 907.766.3373

November 27, 2012

TO ALL BID DOCUMENT HOLDERS
BARNETT DRIVE BOLTED STEEL WATER TANK

The following addendum was issued today. Please acknowledge receipt of the addendum on your bid documents. Thank you.

Sincerely,

A handwritten signature in blue ink, appearing to read "Michelle Webb", is written over a horizontal line.

Michelle Webb
Deputy Clerk

ADDENDUM NO. 1 TO THE CONTRACT
for the
HAINES BOROUGH
BARNETT DRIVE BOLTED STEEL WATER TANK

Item no. 6

ADD the following note to Drawing C-2 "WATER SERVICE SHALL BE MAINTAINED TO AND FROM THE EXISTING PUMP BUILDING DURING CONSTRUCTION. CONTRACTOR SHALL INSTALL THE 8" RJ DIP TO BARNETT DRIVE IN ACCORDANCE WITH THE PLANS AND SPECIFICATIONS BEFORE DISCONNECTING THE EXISTING A/C PIPE AND BEGINNING DEMOLITION OF THE EXSITING TANK FOUNDATION FOR THE WOOD STAVE TANK AND DEMOLITION OF THE OLD BUILDING SHOWN ON DRAWING C-1. THE EXISTING 8" VALVE TO THE WOOD STAVE TANK WILL ALREADY BE CLOSED FOR REMOVAL OF THE WOOD STAVE TANK BY OTHERS."

By:  _____

Julie Cozzi, Borough Clerk

Total number of pages contained within this Addendum: 2