

Adopted

HAINES BOROUGH, ALASKA
RESOLUTION No. 21-05-916

A Resolution of the Haines Borough Assembly authorizing the Borough Manager to execute a contract with PDC Engineers for the Haines WWTP Influent Inflow and Wet Well project design for an amount not-to-exceed \$42,969.

WHEREAS, the Haines WWTP is an aging system that often requires Borough staff to perform repairs to keep the system running; and

WHEREAS, the existing influent wet well does not allow a way to shut off inflow of influent in a manner that is safe for staff to perform repairs; and

WHEREAS, the current well is also housed inside a building making it difficult for staff to perform maintenance and repairs on the lift station; and

WHEREAS, design and construction of a new wet well will allow staff to safely control flow during maintenance, and an external well will also allow staff to safely and easily service the pumps; and

WHEREAS, both measures will increase safety for our WWTP staff and the WWTP budget has enough funds to cover the design of a new wet well,

NOW, THEREFORE, BE IT RESOLVED that the Haines Borough Assembly authorizes the Borough Manager to execute a contract with PDC Engineers for the Haines WWTP Influent Inflow and Wet Well Upgrade project design for an amount not-to-exceed \$42,969.

Adopted by a duly-constituted quorum of the Haines Borough Assembly on this 25th day of May 2021.

Attest:


Alekka Fullerton, CMC, Borough Clerk




Douglas Olerud, Mayor