

From: [Glacier Glass Works](#)
To: [David Long](#)
Subject: Public comments and questions Portage Cove Trails/Tlingit park trails
Date: Thursday, August 5, 2021 9:12:50 AM

EXTERNAL EMAIL: Do not open links or attachments unless you recognize the sender and know the content is safe.

Dave,

While walking the Tlingit park project and reviewing the 35% plans for the the trails, I noticed that the proposed concrete ramp will be a large structure as proposed situated parallel to Front Street because it is not taking advantage of the existing terrain. Turning the structure 90 degrees would take advantage of the side slope of the drainage channel and reduce the size and material required to build this feature.

Regarding the Portage Cove Trail project, segment 6B is an excellent solution for providing pedestrian safety since Beach Road has no shoulder available for pedestrians from the CIA dock, through the S-curves to Portage Cove Campground.

I do not see any provision for preventing four wheelers access to the trail segments. Will there be bollards or boulders that will prevent vehicles accessing the beach portions of the entire trail project?

Although this is probably just an oversight, I noticed that catch basin CB-4 has no outlet pipe shown. Also the fire hydrant in Segment 6B at approximate STA 44+35 is shown near the valley gutter, taking up room on the sidewalk and would likely struck by snowplows in the winter. This hydrant should be moved to the back of the sidewalk.

Thank you for your time.

Sincerely,
Thom Andriesen